

Smart, Mark

From: Sabre Strout <sstrout@nycoa.com>
Sent: Thursday, February 6, 2020 8:22 AM
To: Pastrana-Del Valle, Solanch; STEPHANIE.LARSON@DES.NH.GOV
Subject: NPDES NH0000116 Non-contact Cooling Water pH
Attachments: ATT00001.txt

Categories: EZ Record - Shared

Good afternoon,

Sampling the non-contact cooling water this morning indicates pH readings outside of the permit range. The Merrimack River intake grab samples were low therefore resulting in effluent grab samples to be outside of the permit range.

- 2/6/2020
 - o Intake pH: 6.1
 - o Effluent pH: 6.0

Please let me know if you have any questions.
Thank you,

Sabre Strout

EHS & Security Coordinator



Nylon Corporation of America

333 Sundial Avenue

Office: (603) 627-5150 Ext. 318

Mobile: (603) 397-7010

Email: sstrout@nycoa.com